


Notice of Completion of an Environmental Screening Report

McGraw Falls G.S. Hydroelectric Project

McGraw Falls Water Power (MFWP) is proposing to develop a 2 MW hydroelectric plant on the Matawin River at the McGraw Falls Dam, 7km southwest of Shabaqua Corners. A rubber dam will be added to the existing weir and will work in coordination with the existing reservoir upstream. The powerhouse will be located approximately 150m downstream of the dam. A wood pole distribution line will run 5km northwest along the existing roadway connecting to the existing line to the Shabaqua Distribution Station.

The proposed Project is subject to the Ontario Environmental Assessment Act and Regulation 116/01. Under this Act and its supporting regulations, the Project is subject to an environmental screening. The Environmental Screening Report examined the Project's potential impacts on the environment including water, wildlife and vegetation. Issues raised by stakeholders and submitted to the proponent have also been considered in the screening report.



The proposed Project has been assessed in accordance with the Environmental Screening Process for electricity projects, the results of which are described in the McGraw Falls G.S. Environmental Screening Report (ESR). The conclusions of the ESR indicate that there are no significant negative effects, subject to mitigation measures as detailed in the ESR. Environmental monitoring programs will be conducted to document the effectiveness of these measures. MFWP intends to proceed with additional permitting requirements and water management planning.

Hard copies of the ESR may be found starting **Wednesday April 1st, 2009 until Friday May 1st, 2009** at the following public locations:

The Brodie Resource Library 216 Brodie St. Thunder Bay	KBM Forestry Consultants Inc. 349 Mooney Ave. Thunder Bay	Thunder Bay City Clerks Office 600 Victoria Avenue East Thunder Bay
---	--	--

The ESR may also be reviewed on the project website www.mcgrawfallspower.ca starting **Wednesday April 1st, 2009**. MFWP must receive all comments regarding the McGraw Falls G.S. hydroelectric project and/or the ESR, in writing, **no later than 4:30pm Friday May 1st, 2009**. All comments and correspondence should be sent to:

Leah Deveaux
ORTECH Power
804 Southdown Rd., Mississauga ON; L5J 2Y4
Phone: 1-877-774-6560 ext. 305
Email: info@mcgrawfallspower.ca
www.mcgrawfallspower.ca

In accordance with the EA Guide, stakeholders must first attempt to resolve any outstanding issues with MFWP during the 30 day review period. In the event that issues cannot be resolved during this period, the concerned party may make a written request to the Director of the MOE's Environmental Assessment and Approvals Branch at the address provided below, to elevate the project to an Environmental Review or Individual Environmental Assessment. A copy of this elevation request must also be sent to MFWP at the address above. Requests must be made in accordance with the provisions set out in the Ministry of the Environment's "Environmental Screening Process for Electricity Projects" (The Guide). The Director must receive requests, at the address below for elevation requests by **4:30pm Friday May 1st, 2009**. A copy of The Guide can be found on the MOE's website. www.ene.gov.ca

Director of Environmental Assessment and Approvals Branch
Ministry of the Environment
2 St. Clair Avenue West, Floor 12A
Toronto, ON; M4V 1L5